



Product certificate K95352/03

Issued 2022-09-01

Replaces K95352/02

Page 1 of 2

CERTIFICATE

Heat exchangers

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Q-Blue

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K656 "Heat exchangers intended for the indirect heating of drinking water" dated 01-02-2012.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

NL.Kiwa.info@Kiwa.com

www.kiwa.nl

Company

Q-Blue

Willem Barentszstraat 5

7825 VZ EMMEN

The Netherlands

Tel. +31 (0)591-630003

info@q-blue.nl

Certification process
consists of initial and
regular assessment of:

- quality system
- product



Heat Exchangers

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

- Showersave®QB1 -serie;
- Q-Blue Recoh-Vert V6.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA 

Place of the mark: on the identification plate of each heat exchanger.

Compulsory specifications:

- Trade mark/type or logo,
- Construction (single-partition/double-partition),
- Secondary side wall material used,
- Intended purpose of use of the connection ends,
- Year of manufacture,
- Primary side working pressure,
- Secondary side working pressure,
- Designation of liquid intermediate medium,
- Maximum primary water temperature,
- Maximum secondary water temperature.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are intended to be used in hot water installations with a working pressure of maximum 1 MPa (10 bar) and a water temperature of maximum 90 °C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Q-Blue
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.