


# CERTIFICATE

Certified Passive House Component

Component-ID 1044sr03 valid until 31st December 2025

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany



Category: **Drain water heat recovery**

Manufacturer: **Q-Blue B.V.,  
Emmen,  
Netherlands**

Product name: **Showersave QB1-21**

**This certificate was awarded based on the following criteria:**

Tested under standard boundary conditions<sup>1</sup> the system reduces the useful energy demand for shower by

57%  $\geq$  30%

## Further properties

Pressure drop tap water at 8 l/min: 0.32 bar

Connection tap water: 1/2" IG

Connection waste water: DN 50

nominal efficiency
69 %
effective dead time
5 s
design flow rate
8 l/min



<sup>1</sup>Balanced flow rates, cold water temperature 10 °C, Temperature at shower head 40 °C, waste water temperature 35 °C, negligible pipe length, shower time 6 min, flow rate 8 l/min

Passive House  
efficiency class

phE

phD

phC

phB

phA

phA+

all climate zones



**CERTIFIED  
COMPONENT**

Passive House Institute