

number	93835/02	Replaces	93835/01
Date of issue	11-12-2017	Issued first	23-11-2016
		Report number	161000141

Declaration  
**regarding the efficiency of a shower heat recovery unit**

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

**Q-Blue B.V.**

This declaration does not pass a judgment on other products supplied by the manufacturer.


The product was tested according the procedure according annex B of the NEN7120:2011/C2:2011.

**PRODUCT NAME**

**Showersave®-QB1-21**

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance ( $\Delta P$ ) (bar)
3	9.2	73	65.0	0.30
4, 5, 6	12.5	100	61.4	0.52

Allard Slomp  
Productmanager



Kiwa Nederland B.V.

Kiwa Nederland B.V.  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
Tel. 088 998 33 55  
Fax 088 998 36 85  
E-mail [eup@kiwa.nl](mailto:eup@kiwa.nl)  
[www.kiwa-eup.nl](http://www.kiwa-eup.nl)

Q-Blue B.V.  
Willem Barentszstraat 5  
7825 VZ EMMEN  
The Netherlands  
+31 (0) 591 374570  
[info@q-blue.nl](mailto:info@q-blue.nl)  
[www.q-blue.nl](http://www.q-blue.nl)

