

number 94527/01 Replaces -
Date of issue 19-01-2017 Issued first 19-01-2017
Report number 161000141/1

**Declaration
regarding the efficiency of a shower heat
recovery unit**

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

Q-Blue B.V.

This declaration does not pass a judgment on other products supplied by the manufacturer.


The product was tested according the procedure according annex B of the NEN7120:2011/C2:2011.

PRODUCT NAME

Showersave®-QB1-12

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
3	9.2	73	52.7	0.24
4, 5, 6	12.5	100	48.5	0.42

Allard Slomp
Productmanager



Kiwa Nederland B.V.
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
Tel. 055 539 33 55
Fax 055 539 34 62
E-mail info@kiwa.nl
www.kiwa.nl

Manufacturer:
Q-Blue B.V.
Willem Barentszstraat 5
7825 VZ EMMEN
The Netherlands
+31 (0) 591 374570
info@q-blue.nl
www.q-blue.nl

