

94529/01 number 19-01-2017 Date of issue

Replaces Issued first

19-01-2017

161000141/1 Report number

Declaration regarding the efficiency of a shower heat recovery unit

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

Q-Blue B.V.

This declaration does not pass a judgment on other products supplied by the manufacturer.

The product was tested according the procedure according annex B of the NEN7120:2011/C2:2011.

PRODUCT NAME

Showersave®-QB1-21D

class	Flow	Volume	Efficiency	Flow resistance
				(ΔP)
\frown) _	(l/min)	(1)	(%)	(bar)
3	9.2	73	70.4	0.13
4, 5, 6	12.5	100	69.3	0.20

Allard Slomp Productmanager

up

Manufacturer: Q-Blue B.V. Willem Barentszstraat 5 7825 VZ EMMEN The Netherlands +31 (0) 591 374570 info@q-blue.nl www.q-blue.nl



Kiwa Nederland B.V. Wilmersdorf 50 Postbus 137 7300 AC Apeldoorn Tel. 055 539 33 55 Fax 055 539 34 62 E-mail info@kiwa.nl www.kiwa.nl